

Appendix D – JWPCP Background and NDN




SANITATION DISTRICTS OF LOS ANGELES COUNTY

JWPCP Background





JWPCP Water Quality



	Unit	Influent	Primary Effluent	Secondary Effluent
BOD	mg/L	460	240	<5
COD	mg/L	740	370	55
TSS	mg/L	530	150	15
NH ₄ -N	mg N/L	41	45	42
TKN	mg N/L	64	58	44
TP	mg P/L	8.8	7.0	0.59



HPOAS Process

8 Treatment Units (Each Unit: Reactor + 26 Final Clarifiers)
Currently Operating 6 Treatment Units

Parameter	Unit	Design	Current Operation
Average Flow	MGD	50	54
Reactor			
Hydraulic Retention Time (HRT)	Hours	2.5	2.3
RAS Recycle Ratio	%	30	30
MLSS	mg/L	4,000	3,300
Final Clarifiers			
Overflow Rate	gpd/ft ²	550	590
Solids Loading Rate	lb/ft ² -d	24	22
Mean Cell Residence Time (MCRT)	Days	3.5	3.4
MCRT (Reactor Only)	Days	--	2.3
Aerobic MCRT (Reactor Only)	Days	--	1.8




Operate HPOAS to Nitrify Only

- Minimum aerobic MCRT: 1.5 days @ 25°C, 0.9 days @ 30°C →
Operating aerobic MCRT: 5 – 8 days for reliable nitrification
- Need to increase MLSS by decreasing sludge wasting → high MLSS could cause solids loading to exceed design criteria for clarifiers
- Operate one more treatment unit
→ One unit operated at <50 MGD (35 MGD?)
- More oxygen required
 - 270 tons/d O₂ used for COD stabilization
 - Additional 250 tons/d O₂ required to fully nitrify
- Existing HPOAS plants rarely operated in single-sludge nitrification mode



Nitrification and Denitrification (NDN)




Parameter	Unit	Water Reclamation Plants	JWPCP
HRT	Hours	6 – 8	2.5
MLSS	mg/L	4,000 – 6,000	3,300
MCRT	Days	15	3.4
RAS Recycle	%	100	30
Internal ML Recycle	%	250 – 300	None

Significant “derating” expected (50 MGD → 25 MGD?)




NDN without Derating (MBR Treating Primary Effluent)



- MLSS: 8,000 – 10,000 mg/L
- MCRT: 15 days
- Significant modifications of existing systems (pumping, membranes)
- Expensive



MBR Fully Nitrifies JWPCP Effluent





Water Quality - MBR vs. UF

Parameter	Units	JWPCP Effluent	MBR Permeate	UF Permeate
pH (Field)	-	7.1	7.0	7.3
Ammonia	mg N/L	37	<1.0	36
TKN	mg N/L	40	<1.0	38
Nitrate	mg N/L	<0.10	39	<0.10
Nitrite	mg N/L	0.03	0.02	0.04
Phosphate	mg P/L	0.50	0.29	0.25
COD	mg/L	55	32	--
TOC	mg/L	16	9.2	13
Alkalinity, Total	mg CaCO ₃ /L	373	100	372




Summary of MBR Advantages

- Removes biodegradable organic matter and degrades some trace organics
 - Better water quality feed to RO
 - RO permeate TOC always < 0.5 mg/L
- Fully nitrifies secondary effluent → less acid needed for pH adjustment upstream of RO
- Less fouling, less cleaning time vs. UF
- Membranes can be operated at 23 gfd (similar to UF membranes treating non-NDN secondary effluent)




Nitrify JWPCP Effluent Upstream of UF-RO with Biological Aerated Filter (BAF)





Biological Aerated Filter


- Up-flow reactor with proprietary media for biofilm attachment
- Applications: nitrogen removal with simultaneous particle removal
- Several manufacturers (Kruger, IDI, BKT)





BAF Operations

- Up-flow filtration (operation)
- Gravity based down-flow backwash
- Particles are filtered by the floating media





BKT's BAF Pilot System




- One column for nitrification and one for denitrification (need external electron donor)
- Expanded polypropylene media
- Title 22 approved for tertiary filtration





Schematic Diagram






Operating Conditions of Nitrifying BAF

Parameters	Units	Flow (gpm)			
		1.7	2.6	3.3	4.0
Empty Bed Contact Time	min	52	34	27	22
Hydraulic Loading Rate	gpm/ft ²	0.9	1.3	1.7	2.0
NH ₄ -N Loading Rate	lb N/1000 ft ³ -d	65	95	124	146
	Kg/m ³ -d	1.0	1.5	2.0	2.4
DO	mg/L	5.0~6.5			
Temperature	°F	78~93			



Nitrification Capacity of Nitrifying BAF






Nitrifying BAF Performance

Parameters	Units	Influent			Effluent		
		Average	Min	Max	Average	Min	Max
NH ₄ -N	mg N/L	38.1	34.9	40.5	4.2	<1	12.4
NO ₃ -N	mg N/L	ND	-	-	31.2	20.8	37
NO ₂ -N	mg N/L	ND	-	-	2.7	0.1	8.54
Alkalinity	mg CaCO ₃ /L	333	218	380	118	92	130
COD	mg/L	58	43	75	48	41	61
BOD	mg/L	3.5	3	4	-	-	-
TSS	mg/L	10.5	9	12	5.0	3.1	7.9
Turbidity	NTU	4.4	2.3	16	1.5	0.8	2.5




Nitrifying BAF COD Removal





Nitrifying BAF TSS Removal





Summary

- JWPCP's HPOAS system is not designed for nitrification or biological nitrogen removal; upgrade would result in substantial derating or significant costs.
- JWPCP effluent can be nitrified separately; options include MBR or nitrifying BAF followed by UF.
- MBR-RO-AOP has been extensively tested and has a number of advantages.



Wastewater Treatment Facilities Map



JOINT WATER POLLUTION CONTROL PLANT - JWPCP

Photo of Early Plant Operation






Aerial View of the JWPCP 285 MGD



JWPCP Treatment Areas



JWPCP PROCESS FLOW



J.O.-B SEWER





Primary Treatment Area



Odor Control Stations



Primary Sedimentation Basins



Grit Chambers



Inlet Works

Inlet Works



An aerial photograph of a wastewater treatment plant. The image shows several long, rectangular concrete basins. In the foreground, a row of four large, tan-colored electric motors is mounted on concrete bases, connected to long horizontal shafts that extend into the basins. These are inlet pumps. To the right, there are more basins with complex piping and structures, including a large, curved pipe. The ground is paved, and a white pickup truck is visible in the background. The sky is clear and blue.

*Aerated Grit
Chambers &
Inlet Pumps*

An aerial photograph of a wastewater treatment plant. The foreground is dominated by a large, rectangular primary sedimentation tank with a grid of metal walkways. A thick, tan-colored pipe runs horizontally across the middle of the frame. In the background, there are several vertical cylindrical tanks and a building with a stone facade. The sky is clear and blue.

***PRIMARY SEDIMENTATION TANKS &
SECONDARY INFLUENT PUMP STATION***

Anaerobic Digesters





Power Generation





Two Stage Treatment of Air in Primary Treatment

Biotricking Filters + Activated Carbon





Secondary Treatment




Reactors



Clarifiers

Secondary Treatment Reactors & Clarifiers





Reactor Influent Force Main

Reactors

A

B

C

D

E

F

G


H

Clarifiers

Effluent Channel




JWPCP Secondary Oxygen and Liquid Process Flows Arrangement No. 1






JWPCP Secondary Oxygen and Liquid Process Flows Arrangement No. 2

Mixed Liquor To 2° Clarifiers





Activated Sludge Process



Cryogenic Oxygen Separation Plants





JWPCP Tunnel/Outfall

2 Tunnels

4 Outfalls

- 2 miles out
- Over 160 feet below surface




FIGURE 4.3.11.2
TUNNELS AND OUTFALLS
PLAN AND PROFILE



Solids Handling Facility




Dewatering Building



Truck Loading Stations



Biosolids Handling Facility Biofilters





Questions?

